


Smoke and Dye Testing Summary

High Level Sewershed

Run Summary

Test ID	Test Type	Date Inspected	Company / Super.	Blower MH	Ground Condition	Notification Made?	Total Length
S1028-210	Smoke	8/4/2009	ADS/TM	S17A_013MH	Dry	Yes	1,087.75



Smoke and Dye Testing Summary

High Level Sewershed

Run Summary

Test ID	Test Type	Date Inspected	Company / Super.	Blower MH	Ground Condition	Notification Made?	Total Length
S1028-210	Smoke	8/4/2009	ADS/TM	S17A__013MH	Dry	Yes	1,087.75

Isolated Pipes

Pipe ID	Upstream MH	Downstream MH	Length (ft)	Diameter (In)
S17A__023G1	S17A__023DE	S17A__013MH	339.907	12
S17A__013G1	S17A__013MH	S17A__002MH	443.46	12
S17A__002G1	S17A__002MH	S17A__001MH	41.0811	8
S17A__001G1	S17A__001MH	S17C__005MH	263.303	8

Observations & Photos

Obs_ID S1028-210-OB01

Address 2404 Arunah Ave

Status Private

Source Cleanout

Location Yard - back

Nearest MH S17A__013MH

Comments Smoke from cleanout in back yard. 2404 Arunah Ave.



Picture \S1028-210-OB01-P01.jpg

Comments Back of house, 2404 Arunah Ave.

Obs_ID S1028-210-OB02

Address 2403 Harlem Ave

Status Private

Source Cleanout

Location Yard - back

Nearest MH S17A__013MH

Comments Smoke from cleanout in back yard. 2403 Harlem Ave.



Picture \S1028-210-OB02-P01.jpg

Comments Back of house, 2403 Harlem Ave.

Smoke and Dye Testing Summary

High Level Sewershed

Run Summary

Test ID	Test Type	Date Inspected	Company / Super.	Blower MH	Ground Condition	Notification Made?	Total Length
S1028-210	Smoke	8/4/2009	ADS/TM	S17A__013MH	Dry	Yes	1,087.75

Obs_ID S1028-210-OB03

Address 2408 Arunah Ave

Status Private

Source Cleanout

Location Yard - back

Nearest MH S17A__013MH

Comments Smoke from cleanout in back yard. 2408 Arunah Ave.



Picture \S1028-210-OB03-P01.jpg

Comments Back of house, 2408 Arunah Ave.

Obs_ID S1028-210-OB04

Address 2410 Arunah Ave

Status Private

Source Cleanout

Location Yard - back

Nearest MH S17A__013MH

Comments Smoke from cleanout in back yard. 2410 Arunah Ave.



Picture \S1028-210-OB04-P01.jpg

Comments Back of house, 2410 Arunah Ave.